

Annexure D

BUILDING SAFETY CERTIFICATE

No 02/AE-DCap/24-25

Dated: 04/03/25

It is certified that the existing building Narayana E- Techno School (name of the building or premises) at Beirri Akbarpur, Kaschor Mainawati Marg Kanpur Nagar (address) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	one Basement + G+2 Floor					

The building is owned/occupied by Narayana Educational Society (name of the Institution) have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of G.D.B. P.W.D. Kanpur (Name of Department/ Govt.) on 04-March-25 (date of inspection) in the presence of Shri Shailendra Yadav (name and addresses of the Manager/Secretary or his representative) and that the building/premises is fit for occupancy for running school with effect from 04-03-2025 for a period of 03 (three) years in accordance with rule and subject to compliance of the specific conditions as appended.

1. Ramp and Railing provided for Physically handicapped student
2. Floor to Ceiling height Measured 3.45 mt
3. Staircase Riser 15.0cm Tread 30.0cm and width 1.5 mt
4. Fire safety (Engushers) set Each floor.

Issued on 04-March-2025 at Mainawati Marg Kanpur Nagar

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal : 

Name : Rahul Singh

Designation : Assistant Engineer

Name & Address of Department/ Office: Cons. Div Building P.W.D Kanpur Nagar

सहायक अभियंता
निर्माण खण्ड भवन, लोठ निठ विठ
कानपुर नगर