Annexure D

BUILDING SAFETY CERTIFICATE

Ref No. ST 01 **Dated:** 21.06.2026

It is certified that the existing building **NARAYANA E TECHNO SCHOOL** at **S.F.No: 366/5B2, ELAVAMALAI VILLAGE, ERODE TALUK, ERODE – 638316** is having 1 - block / Ground + 3 Upper Floors as per details below:

Detail of Block(s) in School	**Block (1)**
No. of Floor(s) in the Block	**Ground + 3 Upper Floors**

The building is owned/occupied by **NARAYANA E TECHNO SCHOOL** have complied with the building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **INFINUM DESIGN & CONSULTANTS** on **21.06.2026** (date of inspection) in the presence of **Er. K M RAGUNANTHAN, 97, 1st Floor, Penna Tower, Near Oxford Hotel, Veerapathra Street, Erode-638003** (name and addresses of the Manager / Secretary or his representative) and that the building / premises is fit for occupancy for running school with effect from **22.06.2026** for a period of **03 (Three)** years in accordance with rule and subject to compliance of the specific conditions as appended.

1. The work has been completed to my best satisfaction.
2. The workmanship & all the materials have been used strictly in accordance with general and details satisfaction
3. The building is structurally sound, safe and hygienic. Based on the future maintenance
4. Hence it is fit for use how in with Narayana e Techno School is running.

Issued on **21.06.2026** at **ERODE**

* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

Signature with Seal

Er. K.M. Ragunanthan
B.E., M.Tech(Str)., A.I.V., C.E(Struct.).,
Structural Consultant, Approved Valuer
Chartered Structural Engineer,
CE/ISE/LM/111985-24
Pannel Engineer for Public Building
License Class II-TN 00 726 EMP00202
97, 1st Floor, Penna Tower Near Oxford Hotel,
Veerapathra Street, Erode - 638 003.

CamScanner

STABILITY CERTIFICATE

Er K. M. RAGUNANTHAN

B.E., M.TECH(STR)., A.I.V.,

PANNEL ENGINEER
FOR PUBLIC BUILDING LICENSE | CHARTERED
STRUCTURAL ENGINEER | APPROVED VALUER

GOOD STRUCTURES ARE BUILT, NOT BY CHANCE,
BUT BY GOOD DESIGN.

TO NARAYANA e-TECHNO SCHOOL



MOBILE: 9786574672

ADDRESS FIRST FLOOR, PENNAR TOWER

STRUCTURAL SOUNDNESS CERTIFICATE

[As per Tamil Nadu Public Buildings (Licensing) Act, 1965]

Registration No of the Engineer: TN00726EMP00202

Name of the Engineer: RAGUNANTHAN K M

Class: CLASS II

District: Coimbatore,Erode,Karur,Namakkal,Salem,Tiruppur,

Structural Soundness Certificate Number: TN00826ERD00298

Applicant Details:

1. Name of the Institution: NARAYANA e TECHNO SCHOOL

2. Name of the owner: Mr Shanmugam Perumal

3. Address: SF No 366/5B2, Elavamalai Village, Erode Taluk, Erode District

4. Survey Number: 366/5B2

5. Ward Number:

6. District: Erode

7. Taluk: Erode

8. Village/ Town: Chithode

9. Pin code: 638316

Building Details:

1. Area of the Building: 40629 Sq.ft

2. Height of the Building: 15.22 Metres

3. Class of the Building: Class II

4. Foundation

i. Type of foundation: Shallow

K.M.R.

Er. K.M. Ragunanthan B.E.,M.Tech(Str)
Pannel Engineer for Public Building License
Class - II - TN 00726 EMP 00202
97, 1st Floor, Penna Tower, Near Oxford Hotel,
VCTV Road, Erode - 638 003.

ii. Depth below ground level (in Metres): 2.8

iii. Nature of soil met with at foundation level: Soft Weathered Rock

iv. Pressure at foundation (in KN/m^2): 270

v. Probable safe bearing capacity of the strata met with at foundation (in KN/m^2): 360

vi. Maximum Diameter of Pile adopted (in mm): NA

vii. Minimum Diameter of Pile adopted (in mm):NA

viii. Maximum Depth of Pile adopted (in metres):NA

ix. Minimum Depth of Pile adopted (in metres):NA

x. Maximum Load Carrying Capacity of Pile adopted (in KN): NA

xi. Minimum Load Carrying Capacity of Pile adopted (in KN):NA

5. Superstructure

i. Type of Structure: Framed

ii. Classification of Structure: RCC

iii. Maximum stress in the most critical section of masonry and concrete (in KN/m^2): 5300

iv. Nature of masonry and concrete: Brick Masonry and Concrete M25

v. Safe permissible stress (in KN/m^2): 6250

vi. Type of Steel Structure adopted: RCC

vii. Type of connections adopted: RCC

viii. Type of Roofing Materials adopted: RCC

ix. Maximum Span of steel structure adopted (in metre):6.88

x. Minimum Span of steel structure adopted (in metre): 2.44

xi. Maximum cross-sectional dimensions of the columns adopted (in mm):300 X 600

xii. Minimum cross-sectional dimensions of the columns adopted (in mm): 300 x 300

xiii. Maximum cross-sectional dimensions of the beams adopted (in mm): 300 x 600

xiv. Minimum cross-sectional dimensions of the beams adopted (in mm): 230 x 450

xv. Maximum thickness of the slabs adopted (in mm): 200

xvi. Minimum thickness of the slabs adopted (in mm): 150

xvii. Specify any other information: New Building

6. Year of Construction : 2026

7. Number of floors : 4

8. Usage/ Purpose of the building: Educational Institutions

9. Validity period for which the building will be structurally sound: 22-06-2026 to 21-06-2029

K.M.

Er. K.M. Ragunanthan B.E.,M.Tech(Str)
Pannel Engineer for Public Building License
Class - II - TN 00726 EMP 00202
97, 1st Floor, Penna Tower, Near Oxford Hotel,
VCTV Road, Erode - 638 003.

10. Maximum number of persons to be accommodated: 2100

11. Conditions binding the Structural Soundness Certificate: Any structural alteration without prior approval of the Structural Engineer shall render this certificate invalid, and the Structural Engineer shall not be held responsible for any consequences

Self-Declaration:

☑The structural soundness of the building has been verified by me with reference to Indian Standards (Latest version) and other relevant Indian Standard Code of Practice.

☑I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. A licence may be issued for the period from 22-06-2026 to 21-06-2029 inclusive.

☑I declare that this structural soundness Certificate is issued for the Class of Building and in the district for which I am empanelled with. I am aware that any Violation to this may lead to me being permanently disqualified as an empanelled engineer.

☑I hereby certify that I have inspected the building mentioned and the information furnished by me are true and accurate to the best of my knowledge. I understand that any misrepresentation and/or false information may lead to me being disqualified as an empanelled engineer.



Signature of the empanelled engineer:
Er. K.M. Ragunanthan B.E.,M.Tech(Str)
Pannel Engineer for Public Building License
Class - II - TN 00726 EMP 00202
97, 1st Floor, Penna Tower, Near Oxford Hotel,
VCTV Road, Erode - 638 003.

(அ) TN00826ERD00298 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை
https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/ ல் உள்ளீடு செய்து சரிபார்க்கவும்.
(அல்லது)
(ஆ) கைப்பேசியில் பார்கொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.
Genuineness of the certificate can be verified by.
(a)Keying in the unique certificate number TN00826ERD00298 in the URL
https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/
(or)
(b)Reading the 2D barcode with mobile barcode reader and verify through online.

Reference - ST 01	Load Calculation Sheet - NARAYANA e TECHNO SCHOOL						
	Nos	Length	Breath	D/H	Area	Wt/ unit	Weight
Dead Load							
Slab							
FF, SF & TF & Terrace Floor	4	6.15	4.04	0.15	14.91		
Beam							
Plinth, FF, SF, TF & Terrace Floor	5	6.15	0.30	0.45	4.15		
	5	4.04	0.30	0.45	2.73		
Column							
Foundation to Terrace	1	0.30	0.60	18.02	3.24		
					25.03	**2500.00**	**62574.00**
Super Dead Load							
FF, SF & TF	3	6.15	4.04		**74.54**	**300.00**	**22361.00**
Terrace	1	6.15	4.04		**24.85**	**300.00**	**7454.00**
Floor Finished Load							
FF, SF & TF	3	6.15	4.04	0.05	3.73		
Terrace	1	4.04	6.15	0.10	2.48		
					6.21	**2500.00**	**15529.00**
Live Load							
FF, SF & TF	3	6.15	4.04		74.54		
					74.54	**400.00**	**29815.00**
Terrace	1	6.15	4.04	0.05	**24.85**	**200.00**	**4969.00**
Masonary Load / Partician Load							
GF, FF, SF, TF & Terrace Floor	4	6.15	0.23	2.75	15.56		
	4	4.04	0.23	2.75	10.22		
					25.78	**2200.00**	**56718.00**
					Say		**199420.00**
Add 10 % for foundation							19942.00
		L	B				**219362.00**
Footing		2.70	3.00		8.10		**27081.73**
					Pressure on soil	**27.08**	**T /M2**
					Allowable Safe bearing capacity	**36.00**	**T /M2**
				27.08	<	**36.00**	
Hence Safe							

Er. K.M. Ragunanthan B.E.,M.Tech(Str)
Pannel Engineer for Public Building License
Class - II - TN 00726 EMP 00202

Government of Tamil Nadu
Certificate of Registration for Empanelled Engineers
[Under Rule 11 of Tamil Nadu Public Buildings (Licensing) Rules, 1966]

Name of the Engineer : RAGUNANTHAN K M
Registration No : TN00726EMP00202
Districts Empanelled : Coimbatore,Erode,Karur,Namakkal,Salem,Tiruppur

This is to certify that you have been officially **Empanelled** as an **CLASS II** Engineer in district(s) mentioned above. Your qualifications and experience are taken on record.

- That the Engineer is authorised to inspect and provide Structural soundness certificate only to the class of buildings in the respective districts for which he/she is authorised (see note below).
- The Empanelled Engineer Certified under this order shall bear the responsibility for every Structural Soundness Certificate issued therein.
- Any misrepresentation and/ or false information submitted shall lead to immediate suspension/ cancellation and the engineer shall be permanently debarred from taking up any works under the Government or local body and may be subjected to legal action.

Note :

- Engineers Empanelled under Class I are authorised to provide structural Soundness certificate to Class I, Class II and Class III Buildings.
- Engineers Empanelled under Class II are authorised to provide structural Soundness certificate to Class II and Class III Buildings.
- Engineers Empanelled under Class III are authorised to provide structural Soundness certificate only to Class III Buildings.

Digitally signed by SABAPATHY MANIVANNAN
Date: 2026.05.29 11:08:47 +05:30

Engineer-in-Chief,

Public Works Department

K.M.R.

Er. K.M. Ragunanthan B.E.,M.Tech(Str)
Pannel Engineer for Public Building License
Class - II - TN 00726 EMP 00202
97, 1st Floor, Penna Tower, Near Oxford Hotel,
VCTV Road, Erode - 638 003.

(அ) TN00726EMP00202 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை
https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/ ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பார்கொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00726EMP00202 in the URL
https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.

ஈரோடு வருவாய் வட்டாட்சியரின் செயல்முறைகள்
பிறப்பிப்பவர் : திருமதி. ந. கவிதா, பி.ஏ.,

மூ.மு.எண்: 4577/2026/அ4 நாள்: 31.07.2026.

பொருள்: பொதுக்கட்டிட உரிம விதிகள் - ஈரோடு வட்டம் - S.F.No. 366/5B2, எலவமலை கிராமம் என்ற முகவரியில் இயங்கி வரும் NARAYANA e TECHNO SCHOOL கட்டிடத்திற்கு பொதுக் கட்டிட உரிமம் வழங்க கோரியது - தொடர்பாக.

பார்வை: 1. NARAYANA e TECHNO SCHOOL மனு நாள்: 20.07.2026
2. தீயணைப்பு மீட்புப்பணி நிலையம், நிலைய அலுவலர், ஈரோடு அவர்களின் LICENCE NO.C.R.NO.246/2026 DATED 03.07.2026
3.ERODE DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE CERTIFICATE NO TN00126ERD37476 Dated: 08.06.2026

உத்தரவு :

ஈரோடு வட்டம், S.F.No. 366/5B2, எலவமலை கிராமம் என்ற முகவரியில் இயங்கி வரும் NARAYANA e TECHNO SCHOOL கட்டடத்திற்கு பொதுக் கட்டட உரிமம் வழங்க கோரிய மனு பரிசீலனை செய்யப்பட்டு பொது கட்டட உரிமம் எண்: 18/2026-னை 22.06.2026 முதல் 21.06.2029 வரையிலான காலத்திற்கு செல்லத்தக்க வகையில் உரிமம் வழங்கி இதன்மூலம் உத்திரவிடப்படுகிறது.

2. இந்த உரிமம் காலாவதியாவதற்கு 90 நாட்களுக்கு முன்னரே உரிமம் புதுப்பித்தல் மற்றும் அங்கீகாரம் செய்யப்பட்ட பொறியாளரிடம் கட்டட உறுதிச்சான்று மற்றும் வரைபடம் பெற்று இணைத்து ஈரோடு வருவாய் வட்டாட்சியர் அவர்களுக்கு விண்ணப்பம் செய்து கொள்ள வேண்டியது.

3. உரிமம் வழங்கப்பட்ட பின்னர் கட்டடங்களில் ஏற்படும் மாற்றங்கள் குறித்து முன்னரே உரிய அனுமதி பெற வேண்டுமெனவும், தமிழ்நாடு பொதுக்கட்டட உரிம விதிகளின்படி கட்டடங்களை பராமரிக்க வேண்டுமெனவும் தெரிவிக்கப்படுகிறது.

4. உரிமம் மற்றும் வரைபடம் அசலாக இத்துடன் இணைத்து அனுப்பப்படுகிறது.

இணைப்பு : அசல் உரிமம் மற்றும் வரைபடம்.

31.07.26

வருவாய் வட்டாட்சியர்,
ஈரோடு.

பெறுநர் :
NARAYANA e TECHNO SCHOOL
S.F.NO.366/5B2,
ELAVAMALAI VILLAGE,
ERODE TALUK.
ERODE DISTRICT.

31/7/26

K.Dis.No.4577/2026/A4

Taluk Office,Erode
Dated: 31.07.2026.

FORM-D

(From of licence under sub-section(1)of section 6 of the Madras Public Buildings (Licensing) Act,1965(Madras Act,1965) referred to in Rule 6 of the Madras Public Buildings(Licensing) Rules 1965).

ISSUE OF LICENCE

LICENCE NO.17/2026

Licence Fee Rs.5000/-
(Rupees FIVE Thousand only)
Remitted in Chalan
Number. 20260720024323
Dated:20.07.2026 at
SBI,Erode.

Licence is hereby granted to NARAYANA e TECHNO SCHOOL, S.F.NO.366/5B2, ELAVAMALAI VILLAGE, ERODE TALUK, ERODE DISTRICT. building specified in the statement below *and* subject to the conditions and for the period mentioned here under:-

1) The period of Validity of the Licence shall be
From 22.06.2026 To 21.06.2029 (both days inclusive)

31.07.26

TAHSILDAR
ERODE.

STATEMENT OF ACCOMPANY THE LICENCE

Location of the Building (Door No.Street No.and the Name of the place)	Purpose for which the building is licenced to be used as a public building	Number of personsto be accommodated
NARAYANA e TECHNO SCHOOL S.F.NO.366/5B2, ELAVAMALAI VILLAGE, ERODE TALUK. ERODE DISTRICT.	EDUCATIONAL INSTITUTION	2100 PERSONS

31.07.26

TAHSILDAR
ERODE.

TO:
NARAYANA e TECHNO SCHOOL
S.F.NO.366/5B2,
ELAVAMALAI VILLAGE,
ERODE TALUK.
ERODE DISTRICT.

31/7/26

K.Dis.No.4577/2026/A4

Taluk Office,Erode
Dated: 31.07.2026.

FORM-D

(From of licence under sub-section(1)of section 6 of the Madras Public Buildings (Licensing) Act,1965(Madras Act,1965) referred to in Rule 6 of the Madras Public Buildings(Licensing) Rules 1965).

ISSUE OF LICENCE

LICENCE NO.17/2026

Licence Fee Rs.5000/-
(Rupees FIVE Thousand only)
Remitted in Chalan
Number. 20260720024323
Dated:20.07.2026 at
SBI,Erode.

Licence is hereby granted to NARAYANA e TECHNO SCHOOL, S.F.NO.366/5B2, ELAVAMALAI VILLAGE, ERODE TALUK, ERODE DISTRICT. building specified in the statement below and subject to the conditions and for the period mentioned here under:-

1) The period of Validity of the Licence shall be

From 22.06.2026 To 21.06.2029 (both days inclusive)

31.07.26

TAHSILDAR
ERODE.

STATEMENT OF ACCOMPANY THE LICENCE

Location of the Building (Door No.Street No.and the Name of the place)	Purpose for which the building is licenced to be used as a public building	Number of personsto be accommodated
NARAYANA e TECHNO SCHOOL S.F.NO.366/5B2, ELAVAMALAI VILLAGE, ERODE TALUK. ERODE DISTRICT.	EDUCATIONAL INSTITUTION	2100 PERSONS

31.07.26

TAHSILDAR
ERODE.

TO:
NARAYANA e TECHNO SCHOOL
S.F.NO.366/5B2,
ELAVAMALAI VILLAGE,
ERODE TALUK.
ERODE DISTRICT.

31/7/26

SEAL TRANSLATION
TAHSILDAR, ERODE

Attested
28/9/2026

N. PARANITHARAN B.Com., B.L.,
ADVOCATE & NOTARY PUBLIC
586, METTUR MAIN ROAD,
OPP. TALUK OFFICE, BHAVANI,
ERODE DISTRICT, TAMIL NADU, INDIA

NOTARY
N. PARANITHARAN
B.Com., B.L.,
ERODE DISTRICT
Regn No:7569
GOVT. OF INDIA