

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 54/2025

Dated: 11-07-25

It is certified that an inspection team headed by Anand.B. Modiya  
Public Health Supervisor (Name of Officers with designation) from  
Chandlodiya Ward.....PHED inspected the **Narayana e-Techno School** at

**Survey No.:224, T.P.No:233, Final Plot No.:53, Tragad village, Ahmedabad** on

06-07-25 and on the basis of Water Test Report (Attached) bearing

no..... — dated 11-6-25 of Central Laboratory (PHED Lab)

certified that the **Narayana e-Techno School** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 05-07-26

**P.H.S.**  
**ચાંદલોડિયા વોર્ડ ઉ.પ મોન**  
**A.M.C.**

Signature with Seal: Anand.....

Name : Anand.B. Modiya

Designation : Public Health Supervisor

Name & Address of the Office /Department



To:

**Narayana e-Techno School**

**Survey No.:224, T.P.No:233,**

**Final Plot No.:53**

**Tragad village, Ahmedabad, Gujarat-382470**

M. Vaisnav  
**PRINCIPAL**  
**NARAYANA e-TECHNO SCHOOL**  
**TRAGAD, AHMEDABAD**



AHMEDABAD MUNICIPAL CORPORATION  
MAHANAGAR SEVA SADAN  
**CENTRAL LABORATORY**  
(An ISO 9001: 2015 Accredited Laboratory)



Lic No QAC/R91/4650

Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India  
E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438.

June 11, 2025.

To,  
The Principal,  
Narayana e Techno School,  
224 T.P. - 233, F.P. No - 53, Nr. Spandan Heights  
Tragad, Ahmedabad.

Dear Sir,

We have analyzed your water samples collected on Dt. 04-06-2025 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
<b>A. Organoleptic and Physical Parameters</b>				
1	Colour, Hazen units, Max	5	15	0.1
2	pH value	6.5-8.5	No relaxation	6.5
3	Turbidity, NTU, Max	1	5	0.29
4	Total dissolved solids, mg/l, Max	500	2000	74
<b>B. General Parameters</b>				
1	Total hardness (as CaCO <sub>3</sub> ), mg/l, Max	200	600	20
2	Calcium (as Ca), mg/l, Max	75	200	4
3	Magnesium (as Mg), mg/l, Max	30	100	2.44
4	Chloride (as Cl), mg/l, Max	250	1000	20
5	Sulphate (as SO <sub>4</sub> ) mg/l, Max	200	400	< 1.0
6	Total alkalinity (as CaCO <sub>3</sub> ), mg/l, Max	200	600	30
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil
<b>C. Bacteriological Quality of Drinking Water</b>				
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable

**Remarks:**

- The Central Laboratory, AMC, has collected the sample.
- The result contained in this report relate only to the sample material tested.
- The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.

*M. Vaislwan*  
PRINCIPAL  
NARAYANA e-TECHNO SCHOOL  
TRAGAD, AHMEDABAD

*Hiren C. Mandalia*  
Dr. Hiren C. Mandalia  
Scientist In-Charge