



GOVERNMENT OF TELANGANA  
(Medical & Health Department)

**From:**  
Dr.G.Gaythri Devi, MBBS, DPH.,  
Dist.Medl.&Health Officer,  
Sangareddy District.

**To**  
District Educational Officer,  
Sangareddy District,

**Rc.No. 0858/D&O/DM&HO/2025.**

**Dated: 01-05-2025.**

**Sir,**

**Sub:-** D&O ACT – SANITARY CERTIFICATE –Issue of Sanitary Certificate in respect of M/s. Narayana School, sy.No.19/A, Velamal Village, Ramachandrapuram Mandal, Sangareddy District. – Reg.

**Ref:-** Application of the Head Master, M/s. Narayana School, sy.No.19/A, Velamal Village, Ramachandrapuram Mandal, Sangareddy District, Dated 23-04-2025.

**& & &**

Vide reference cited, the Head Master, M/s. Narayana School, sy.No.19/A, Velamal Village, Ramachandrapuram Mandal, Sangareddy District. has applied for Sanitary Certificate. Accordingly the premises of the M/s. Narayana School, sy.No.19/A, Velamal Village, Ramachandrapuram Mandal, Sangareddy District, has been inspected by the authorities of District Medical and Health Office Sangareddy.

**SANITARY CERTIFICATE**

Certified that the sanitary arrangements and amenities provided in the premises of the M/s. Narayana School, sy.No.19/A, Velamal Village, Ramachandrapuram Mandal, Sangareddy District are satisfactory at the time of inspection.

1. That the accommodation provided for each of the several classes is sufficient for the maximum number of pupils taught therein.
2. That the class rooms are properly ventilated and lighted.
3. That it is neat and clean.
4. That the Toilets arrangements are sufficient for 400 (Four Hundred only) students
5. That in all other aspects the sanitation is good.
6. The fire safety arrangements are under proses in the School.
7. Follow the Covid- 19 guidelines issued by Telangana Government

The inspecting authorities are visiting the premises as and when complaints received if any from the students / public.

**This certificate is valid for Academic Year 2025-2026**

This certificate is liable to be cancelled at any time without any prior notice, if the sanitary arrangements are found un-satisfactory.

**Yours faithfully,**

*G. Gayathri Devi*  
Dist.Medl.&Health Officer,  
Sangareddy District.

**Copy to the Head Master, M/s. Narayana School, sy.No.19/ A , Velamal Village, Ramachandrapuram Mandal, Sangareddy District**



# VISON LABS

Environmental Consultants & Analytical Services

Accredited by MoEF & CC  
ISO 9001 : 2015 & OHSAS 45001 : 2018

## TEST REPORT

<b>Issued To:</b> <b>M/s. Narayana School.</b> Survey No: 19/A, Velimela (V), Ramachandrapuram (M), Sanga Reddy (D), Telangana.	Issued Date	29.07.2025	
	Our Ref No	VL-202500014538	
	Your Ref No	Verbal	
	Your Ref Date	23.07.2025	
Sample description given by Customer	<b>Bore Well Water</b>	Mode of Packing	Pet bottle
Appearance of the Sample	Clear Liquid	Sample condition at the time of Receiving	Found Ok
		Sample Quantity	1 ltr
Sample Registration date	23.07.2025	Analysis starting date	23.07.2025
Sample Registration Time	11:35 am	Analysis Completion date	28.07.2025
Sampling done by Customer	<i>Sample Tested As Received Basis</i>		

## TEST RESULTS

S. No	Parameters	Test Method	Units of Measurement	Test Results	Drinking Water Limits As per IS: 10500; 2012	
					Acceptable Limits	Permissible limits in absence of alternative Source

### PHYSICAL EXAMINATION

1.	pH at 25°C	IS:3025 part 11 :2022	--	8.01	6.50 – 8.50	No relaxation
2.	Conductivity at 25°C	IS: 3025 Part 14 2013, RA-2019	µmhos/cm	2255	--	--
3.	Total Dissolved Solids	IS: 3025 Part 16:2023	mg/L	1461	500 max	2000 max
4.	Turbidity	IS: 3025 Part 10:2023	NTU	<1.0	1 max	5 max
5.	Color	IS: 3025 Part 4:2021	CU	<01	5 max	15 max

### CHEMICAL EXAMINATION

6.	Total Hardness as CaCO <sub>3</sub>	IS: 3025 Part 21 2009, RA-2019	mg/L	380	200 max	600 max
7.	Alkalinity – Phenolphthalein	IS: 3025 Part 23 1986, RA-2019	mg/L	<1.0	---	---
8.	Alkalinity – Methyl Orange	IS: 3025 Part 23 1986, RA-2019	mg/L	650	200 max	600 max
9.	Calcium as Ca	IS: 3025 Part 40 1991, RA-2019	mg/L	76.0	75 max	200 max
10.	Magnesium as Mg	IS: 3025 Part 46 1994, RA-2019	mg/L	45.6	30 max	100 max
11.	Chloride as Cl	IS: 3025 Part 32 1988, RA-2019	mg/L	155	250 max	1000 max
12.	Sodium as Na	IS: 3025 Part 45 1993, RA-2019	mg/L	339	---	---
13.	Potassium as K	IS: 3025 Part 45 1993, RA-2019	mg/L	6.6	---	---
14.	Sulphate as SO <sub>4</sub>	APHA 24 <sup>th</sup> Edn 4500 SO4 E, 2023	mg/L	230	200 max	400 max
15.	Nitrate as NO <sub>3</sub>	IS: 3025 Part 34 1988, RA-2019	mg/L	22.9	45 max	No relaxation
16.	Silica as SiO <sub>2</sub>	IS: 3025 Part 35 1988, RA-2019	mg/L	17.5	--	--
17.	Iron as Fe	IS: 3025 Part 53 2003, RA-2019	mg/L	0.24	1.0 max	No relaxation
18.	Fluoride as F	APHA 4500 F B,D 24 <sup>th</sup> Edition:2023	mg/L	0.97	1.0 max	1.5 max

### Microbiological Analysis

1.	Total Plate Count	IS:5402-2012, RA-2018	CFU/mL	82	--
2.	Coli form Bacteria	IS 1622:1981	MPN/100mL	Not Detected	Shall Not be Detectable in any 100 mL
3.	Escherichia coli	IS 1622:1981	MPN/100mL	Not Detected	

Page 1 of 1

Sr. Chemist	Sr. Microbiologist	Authorized Signatory Dr. T. Laxmikanth Reddy- Technical Manager



VL/QM/7. 8/TR

H.No. 1  
Tel : 040-2  
Digitally signed by Narayana  
Date: 2025.07.31 20:47:44 +05:30  
Reason: reason  
Location: location

2nd Floor, Opp. R.T.A. Office, Musarambagh, Malakpet, Hyderabad - 500 036.  
8491 10019 / 94408 41338, E-mail : Info@visonlabs.com, vison.labs@gmail.com  
Report is subject to the terms and conditions mentioned overleaf.



# VISON LABS

Environmental Consultants & Analytical Services

Accredited by MoEF & CC  
ISO 9001 : 2015 & OHSAS 45001 : 2018

## TEST REPORT

<b>Issued To:</b> M/s. Narayana School. Survey No: 19/A, Velimela (V), Ramachandrapuram (M), Sanga Reddy (D), Telangana.	Issued Date	29.07.2025	
	Our Ref No	VL-202500014539	
	Your Ref No	Verbal	
	Your Ref Date	23.07.2025	
Sample description given by Customer	Filter Water	Mode of Packing	Pet bottle
Appearance of the Sample	Clear Liquid	Sample condition at the time of Receiving	Found Ok
		Sample Quantity	1 ltr
Sample Registration date	23.07.2025	Analysis starting date	23.07.2025
Sample Registration Time	11:35 am	Analysis Completion date	28.07.2025
Sampling done by Customer			Sample Tested As Received Basis

## TEST RESULTS

S. No	Parameters	Test Method	Units of Measurement	Test Results	Drinking Water Limits As per IS: 10500; 2012	
					Acceptable Limits	Permissible limits in absence of alternative Source

### PHYSICAL EXAMINATION

1.	pH at 25°C	IS:3025 part 11 :2022	--	6.59	6.50 – 8.50	No relaxation
2.	Conductivity at 25°C	IS: 3025 Part 14 2013, RA-2019	µmhos/cm	44	--	--
3.	Total Dissolved Solids	IS: 3025 Part 16:2023	mg/L	27	500 max	2000 max
4.	Turbidity	IS: 3025 Part 10:2023	NTU	<1.0	1 max	5 max
5.	Color	IS: 3025 Part 4:2021	CU	<01	5 max	15 max

### CHEMICAL EXAMINATION

6.	Total Hardness as CaCO <sub>3</sub>	IS: 3025 Part 21 2009, RA-2019	mg/L	08	200 max	600 max
7.	Alkalinity – Phenolphthalein	IS: 3025 Part 23 1986, RA-2019	mg/L	<1.0	---	---
8.	Alkalinity – Methyl Orange	IS: 3025 Part 23 1986, RA-2019	mg/L	08	200 max	600 max
9.	Calcium as Ca	IS: 3025 Part 40 1991, RA-2019	mg/L	1.6	75 max	200 max
10.	Magnesium as Mg	IS: 3025 Part 46 1994, RA-2019	mg/L	0.96	30 max	100 max
11.	Chloride as Cl	IS: 3025 Part 32 1988, RA-2019	mg/L	05	250 max	1000 max
12.	Sodium as Na	IS: 3025 Part 45 1993, RA-2019	mg/L	5.5	---	---
13.	Potassium as K	IS: 3025 Part 45 1993, RA-2019	mg/L	0.4	---	---
14.	Sulphate as SO <sub>4</sub>	APHA 24 <sup>th</sup> Edn 4500 SO4 E, 2023	mg/L	5.2	200 max	400 max
15.	Nitrate as NO <sub>3</sub>	IS: 3025 Part 34 1988, RA-2019	mg/L	0.6	45 max	No relaxation
16.	Silica as SiO <sub>2</sub>	IS: 3025 Part 35 1988, RA-2019	mg/L	<0.02	--	--
17.	Iron as Fe	IS: 3025 Part 53 2003, RA-2019	mg/L	<0.04	1.0 max	No relaxation
18.	Fluoride as F	APHA 4500 F B,D 24 <sup>th</sup> Edition:2023	mg/L	<0.10	1.0 max	1.5 max

### Microbiological Analysis

1.	Total Plate Count	IS:5402-2012, RA-2018	CFU/mL	<01	--
2.	Coli form Bacteria	IS 15185:2016, RA-2021	CFU/100mL	Not Detected	Shall Not be Detectable in any 100 mL
3.	Escherichia coli	IS 15185:2016, RA-2021	CFU/100mL	Not Detected	

Sr. Chemist	Sr. Microbiologist	Authorized Signatory Dr. T. Laxmikanth Reddy- Technical Manager



VL/QM/7. 8/TR