



VADODARA MUNICIPAL CORPORATION

Health Department – Main Office,
Khanderao Market Building,
Rajmahal Road, Vadodara - 390 001.

Ph.No. (0265)-(2433116), E-mail :- healthmainoffice@gmail.com

H.O.W.No. 361 /2026-27

Date :- 22nd Sept. 2026.


CERTIFICATE

It is certified that an inspection team headed by Dr. Roma Shah, Deputy Health Officer (Name of Officers with designation) from Deputy Health Office (West Zone), Ward No. 12, Near Sahjanand Apartment, Akota, Vadodara PHED inspected the Narayana E-Techno School, Survey No.181/1 & 181/2, TP No.1, Block No.164, F.P. No.77, Opp. Shakti Green Party Plot, Bhayli, Vadodara (Name & Address of the School) on 03/09/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. PHL/PW/0923/2026 dated 20/06/2026 of Public Health Laboratory (PHED Lab) certified that the Narayana E-Techno School (Name of school) is also safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central / State / U.T. Govt.

This certificate is valid till 01 (One) Year (i.e. Up to 22nd September-2027)



Signature with Seal

:- 

Name

:- Dr. Mukesh A. Vaidya

Designation

Chief Health Officer
Vadodara Municipal Corporation

To,
Principal,
Narayana E-Techno School,
Survey No.181/1 & 181/2, TP No.1,
Block No.164, F.P. No.77,
Opp. Shakti Green Party Plot, Bhayli,
Vadodara - 391 410.



PRINCIPAL
NARAYANA e-TECHNO SCHOOL
BHAYLI, VADODARA





PUBLIC HEALTH LABORATORY

VADODARA MUNICIPAL CORPORATION

(NABL Accredited Testing Laboratory as per ISO/IEC 17025 : 2017)



TC-9559

Name and address of Customer (#):
NARAYANA E-TECHNO SCHOOL
SURVEY NO.181/1 & 181/2, TP NO-1, BLOCK NO.164, FP
NO.77, OPP. SHAKTI GREEN PARTY PLOT, BHAYLI VILLAGE,
VADODARA-391410

Test Report No : PHL/PW/0923/2026
Test Report Issue Date : 20-06-2026
Sample Code No. : PW/0905/2026
Sample Received Date : 15-06-2026
ULR Number : TC955926000002165F

Test Report

- (i) Kind of Sample (#) : Drinking Water (R.O.)
(ii) Sample Description : 1 litre water sample received in plastic bottle.
(iii) Sample Condition : Received in good condition.
(iv) Physical Appearance : A clear colourless liquid.
(v) Date of Performance : 15-06-2026 to 20-06-2026.
(vi) Location of Performance : Water Testing Lab.
(vii) Discipline : Chemical.
(viii) Group : Water.

Sr. No.	Quality Characteristic	Name of Method of Test Used	Result	IS 10500:2012 (2 nd Revision)	
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
				Max.	Max.
1	Colour, Hazen unit	APHA (24 th Ed.2022), Method: 2120 B	1	5	15
2	Odour	IS 3025 (Part-5) : 2018	Agreeable	Agreeable	Agreeable
3	Turbidity, NTU	APHA (24 th Ed.2022), Method: 2130 B	0.24	1	5
4	pH at 25°C	APHA (24 th Ed.2022), Method: 4500 H ⁺ B	7.80	6.5 to 8.5	No relaxation
5	Conductivity at 25°C, $\mu\text{S}/\text{cm}$	APHA (24 th Ed.2022), Method: 2510 B	522.00	-	-
6	Total Dissolved Solids, mg/L	APHA (24 th Ed.2022), Method: 2540 C	304.00	500	2000
7	Total Hardness (as CaCO_3), mg/L	APHA (24 th Ed.2022), Method: 2340 C	114.00	200	600
8	Calcium (as Ca^{+2}), mg/L	APHA (24 th Ed.2022), Method: 3500 Ca^{+2} B	16.03	75	200
9	Magnesium (as Mg^{+2}), mg/L	APHA (24 th Ed.2022), Method: 3500 Mg^{+2} B	17.96	30	100
10	Chloride (as Cl^-), mg/L	APHA (24 th Ed.2022), Method: 4500 Cl^- B	94.00	250	1000
11	Sulphate (as SO_4^{-2}), mg/L	APHA (24 th Ed.2022), Method: 4500 SO_4^{-2} E	27.60	200	400
12	Nitrate (as NO_3^-), mg/L	APHA (24 th Ed.2022), Method: 4500 NO_3^- B	< 1.00	45	No relaxation
13	Fluoride (as F^-), mg/L	APHA (24 th Ed.2022), Method: 4500 F^- C	0.10	1	1.5
14	Total Alkalinity (as CaCO_3), mg/L	APHA (24 th Ed.2022), Method: 2320 B	96.00	200	600

Note : Above tests are accredited by NABL

Opinion: In respect of test performed as above, the sample Complies with standard requirement of IS 10500 : 2012 (2nd revision) for drinking water.

PRINCIPAL
NARAYANA e-TECHNO SCHOOL
BHAYLI, VADODARA



(M. L. Patel)
Food Analyst
Public Health Laboratory
Vadodara Municipal Corporation

Note:

1. This Report is refers only to particular sample submitted for testing.
2. This Report is not to be used for the purpose of Advertisement or Legal action.
3. Information marked with "#" is provided by the customer.

End of Test Report



PUBLIC HEALTH LABORATORY

VADODARA MUNICIPAL CORPORATION

Name and address of Customer (#):

NARAYANA E-TECHNO SCHOOL

SURVEY NO.181/1 & 181/2, TP NO-1, BLOCK NO.164, FP

NO.77, OPP. SHAKTI GREEN PARTY PLOT, BHAYLI VILLAGE,

VADODARA-391410

Test Report No : PHL/PW/0923/2026

Test Report Issue Date : 20-06-2026

Sample Code No. : PW/0905/2026

Sample Received Date : 15-06-2026

Test Report

- (i) Kind of Sample (#) : Drinking Water (R.O.)
(ii) Sample Description : 1 litre water sample received in plastic bottle.
(iii) Sample Condition : Received in good condition.
(iv) Physical Appearance : A clear colourless liquid.
(v) Date of Performance : 15-06-2026 to 20-06-2026.
(vi) Location of Performance : Water Testing Lab.
(vii) Discipline : Chemical and Biological.
(viii) Group : Water.

Sr. No.	Quality Characteristic	Name of Method of Test Used	Result	IS 10500:2012 (2nd Revision)	
				Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source
				Max.	Max.
1	Residual Free Chlorine, mg/L	FSSAI Manual Method For Analysis of Foods (Water), 2016	Nil	0.2*	1.0
2	E. Coli	FSSAI Manual Method For Analysis of Foods (Water), 2016	Absent	shall not be detectable in any 100 ml sample	No relaxation

Note : Above tests are not accredited by NABL.

Opinion: In respect of test performed as above, the sample Complies with standard requirement of IS 10500 : 2012 (2nd revision) for drinking water.

A. Ramani

PRINCIPAL
NARAYANA e-TECHNO SCHOOL
BHAYLI, VADODARA



(M. L. Patel)

(M. L. Patel)
Food Analyst
Public Health Laboratory
Vadodara Municipal Corporation

Note:

1. This Report is refers only to particular sample submitted for testing.
2. This Report is not to be used for the purpose of Advertisement or Legal action.
- 3*. To be applicable only when water is chlorinated.
- 4*. When protection against viral infection is required, it should be minimum 0.5 mg/L.
5. Information marked with "H" is provided by the customer.

End of Test Report



Scanned with OKEN Scanner