

# Annexure C

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. - 378

Dated: 25/06/2025

It is certified that an inspection team headed by Mr. Deepak Khare

(Name of Officers with designation) from Assistant Engineer PHED, Jabalpur

inspected the Narayana e-Techno School, Rimgha, Jabalpur (M.P.)

(Name & Address of the school) on 25/06/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. Report No. - 26 dated 23/06/2025

of District Water Testing Laboratory Jabalpur (PHED Lab) certified that


the Narayana e-Techno School Jabalpur (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six Months

  
25/06/25  
Assistant Engineer  
P.H.E. Sub-Division  
Jabalpur

Signature with Seal: Jabalpur

Name: Deepak Khare

Designation: Assistant Engineer

Name & Address of the Office / Department: AE, PHED  
Jabalpur (M.P.)

To  
Narayana e-Techno  
School, Rimgha, Jabalpur (M.P.)  
(Name & Address of the Institution)

Tehsil → Jabalpur  
Jila → Jabalpur (M.P.)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**DISTRICT WATER TESTING LABORATORY**

Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

**WATER TESTING REPORT**

Report no <b>26</b>	Date <b>23/06/2025</b>	Code no. -	
Ref. NO - <b>Nr1</b>	Date <b>23/06/2025</b>	GP/Village & Location	Block
To, <b>Narayana e- Techno School, Rivgha, Tehsil - Jabalpur Jila- Jabalpur (M.P.)</b>		<b>1, Narayana e- Techno School Rivgha, Tehsil - Jabalpur Jila - Jabalpur (M.P.)</b>	
Sample Collected by	<b>Suryam Tiwari</b>	<b>RD water</b>	<b>Jabalpur</b>
Date of collection	<b>23/06/2025</b>		
Source	<b>RD water</b>		
Date of receipt	<b>23/06/2025</b>		
Date of Testing	<b>23/06/2025</b>		
Test conducted by	<b>Poojima Sen</b>		

**As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water**

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	RESULT				
					1	2	3	4	5
<b>PHYSICAL-TEST</b>									
1	Turbidity	NTU	1.0	5.0	<b>1.1</b>				
2	Colour	Pt. Cobalt			<b>-</b>				
3	Taste & Odour	Unobjectionable	Unobjectionable		<b>-</b>				
<b>CHEMICAL-TEST</b>									
4	pH	...	6.5 to 8.5	6.5 to 8.5	<b>7.77</b>				
5	Conductivity	µMohs/cm	..	..	<b>532</b>				
6	Alkalinity	mg/l	200	600	<b>290</b>				
7	Chloride (As cl)	mg/l	250	1000	<b>100</b>				
8	Nitrates	mg/l	45	45	<b>0.0</b>				
9	Total Hardness (As CaCO <sub>3</sub> )	mg/l	200	600	<b>580</b>				
10	Calcium (As Ca)	mg/l	75	200	<b>116.0</b>				
11	Magnesium (As Mg)	mg/l	30	100	<b>70.6</b>				
12	Total dissolved solid	mg/l	500	2000	<b>345</b>				
13	Iron (As Fe)	mg/l	1.00	1.0	<b>0.0</b>				
14	Manganese (As Mn)	mg/l	0.10	0.30	<b>0.0</b>				
15	Fluoride (As F)	mg/l	1.00	1.50	<b>0.0</b>				
16	Sulphates As So <sub>4</sub>	mg/l	200	400	<b>0.34</b>				
17	Residual Chlorine	mg/l	0.20	1.0	<b>-</b>				
<b>BACTERIOLOGICAL-TEST</b>									
18	Total Coliform	per 100ml	0	..	<b>-</b>				
19	E Coli or Thermo tolerant coliforms or Faecal coliform	per 100ml	0	..	<b>-</b>				

Note:- 1.As above result compared with BIS 10500:2012

2.Samples are not collected by us.

3.Not to be produced at court of law.

4.We do not take any responsibility for deviation in test result due to wrong collection of sample

  
**23-06-2025**  
**Asst. Chemist**  
 Public Health Engg. Division  
 Jabalpur (M.P.)