

Annexure C

Office of the Assistant Engineer
Public Health Engg. Sub Division Jabalpur (M.P.)

No. 554

-Dated:- 23/07/2026

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is Certified that an inspection team headed by **Shri Deepak Khare**

From **Assistant Engineer Public Health Engg. Sub Division Jabalpur**

Inspected **Narayana E-Techno School, Rivjha, Tah.- Jabalpur Distt. Jabalpur (M.P.)** On Dt. **23/07/2026** (dt. Of Inspection) and on the basis of Water test report (Attached)

bearing no. **Report No. 46** Dated **22/07/2026** of **District Water Testing Laboratory Public Health Engg. Division Jabalpur (M.P.)** (PHED Lab)

Certified that the **Narayana E-Techno School, Rivjha, Tah.- Jabalpur Distt. Jabalpur (M.P.)** has safe drinking water facilities for the student and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the central/State/U.T. Govt.

This certificate is valid till **Six Months only**

Signature with Seal :-

Name :-

Designation :-

Name & Address of Office :-

(Deepak Khare)

Assistant Engineer

*Public Health Engg. Sub Division
Jabalpur (M.P.)*

23/07/26
Assistant Engineer
P.H.E. Sub-Division
Jabalpur

To,

Narayana E-Techno School ,

Rivjha, Jabalpur (M.P.)

(Name & Address of the Institution)

DISTRICT WATER TESTING LABORATORY
Office of the Executive Engineer, Public Health Engg. Division Jabalpur M.P.

WATER TESTING REPORT

Report No. - 46	Date	22/07/2026	UID No. JBP/
Ref. NO. - Nil	Date	20/07/2026	Village & Location
To,		1- Narayana E-Techno School Rivgha, Jabalpur Campus, Water Source - R.O. water	
Sample Collected by		2-	
Date of collection		/	
Source			
Date of receipt			
Date of Testing			
Test conducted by		3-	

As per BIS 10500:2012 Reaffirmed in feb 2021 For Drinking Water

Sl no.	Characteristic	Unit	Acceptable	Cause for rejection	TEST RESULT	
					1	2

PHYSICAL-TEST

1	Turbidity	NTU	1.0	5.0	1.0	
2	Colour	Pt. Cobalt	1.0	25.0	1	
3	Taste & Odour	Agreeable	Agreeable	Agreeable	Agreeable	

CHEMICAL-TEST

4	pH	...	6.5 to 8.5	6.5 to 8.5	7.82	
5	Conductivity	M. Mohs/cm	..	..	190	
6	Alkalinity	mg/l	200	600	100	
7	Chloride (As Cl)	mg/l	250	1000	25	
8	Nitrates	mg/l	45	45	0.0	
9	Total Hardness (As CaCO ₃)	mg/l	200	600	230	
10	Calcium (As Ca)	mg/l	75	200	48.0	
11	Magnesium (As Mg)	mg/l	30	100	26.78	
12	Total dissolved solid	mg/l	500	2000	123	
13	Iron (As Fe)	mg/l	1.00	1.0	0.0	
14	Manganese (As Mn)	mg/l	0.10	0.30	0.0	
15	Fluoride (As F)	mg/l	1.00	1.50	0.0	
16	Sulphates As SO ₄	mg/l	200	400	0.317	
17	Residual Chlorine	mg/l	0.20	1.0	0	

BACTERIOLOGICAL-TEST

18	Total Coliform	per 100ml	0	..	0	
19	E Coli or Thermo tolerant coliforms	per 100ml	0	..	0	

Remark:-

Note:- 1. As above result compared with BIS 10500:2012

2. Samples are not collected by us.

3. Not to be produced at court of law.

4. We do not take any responsibility for deviation in test result due to wrong collection of sample


Chemist
 District Laboratory
 Jabalpur