



GOVERNMENT OF WEST BENGAL

Health & Family Welfare Department


SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 042/06/26-27

Dated: 30-06-2026

It is certified that an inspection team headed by **Mr. M Mukherjee, Dy. CMOH** inspected the **NARAYANA SCHOOL KRISHNANAGAR** situated at ROAD STATION, SHIMULTALA, OPP: HELIPAD GROUND, KRISHNANAGAR, DIST. - NADIA, WEST BENGAL, PINCODE - 741101 on 29-06-2026 and found that the **NARAYANA SCHOOL KRISHNANAGAR** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1(one) year from the date of issuing of the certificate.


Office of the Dy. CMOH-II
Salt Lake, Kolkata

Chief Medical Officer of Health

SwasthyaBhawan, Sector V

Salt Lake, Kolkata – 700091

(Deputy CMOH-II)

To

NARAYANA SCHOOL KRISHNANAGAR
ROAD STATION, SHIMULTALA,
OPP: HELIPAD GROUND,
KRISHNANAGAR, DIST. - NADIA,
WEST BENGAL, PINCODE - 741101

JADAVPUR UNIVERSITY



SCHOOL OF WATER RESOURCES ENGINEERING

KOLKATA – 700 032

TEST REPORT

OBJECTIVE: - Water Quality Analysis
TESTED FOR: - NARAYANA SCHOOL KRISHNANAGAR

TYPE OF SAMPLE: - RO Filter Output
SAMPLE LOCATION: - NARAYANA SCHOOL KRISHNANAGAR

DATE OF COLLECTION: - 19.06.2026
SAMPLE DRAWN BY: The Party
UNIVERSITY MONEY RECEIPT NO. & DATE: Online Transfer (Axis Bank), transaction ID 21231647231, dated 19.06.2026

Water Quality Analysis - Water quality has been analysed for parameters mentioned below as per Indian Standards (IS) – 10500, 2012 at the laboratory of School of Water Resources Engineering, Jadavpur University. The detailed water quality testing report is attached herewith.

Teachers Involved: Prof. (Dr.) Asis Mazumdar, Prof. (Dr.) Pankaj Kr. Roy


DIRECTOR

SCHOOL OF WATER RESOURCES ENGINEERING
JADAVPUR UNIVERSITY

Prof. (Dr.) Pankaj Kumar Roy
Director

School of Water Resources Engineering
Jadavpur University



REGISTRAR

JADAVPUR UNIVERSITY

Registrar
JADAVPUR UNIVERSITY

Ref no. 11213/23/06/2026

Date 24-June-2026

This report may be published in FULL if necessary, but in no case a part or an abstract thereof may be published, unless permission for the publication of an approved abstract has been obtained in writing from the Registrar, Jadavpur University.



SCHOOL OF WATER RESOURCES ENGINEERING

KOLKATA – 700 032

Water Quality Test Report

Sample not drawn by the School of Water Resources Engineering

SL. NO.	PARAMETERS	RESULTS	Acceptable Limit as per IS 10500, 2012	Permissible Limit as per IS 10500, 2012
1	pH	7.36	6.5-8.5	No Relaxation
2	Electrical Conductivity (EC) (Us/Cm)	187.3	-	-
3	Total Dissolved Solids (mg/L)	92.4	500	2000
4	Turbidity (NTU)	0.31	1	5
5	Total Hardness (as CaCo ₃) (mg/L)	40	200	600
6	Total Arsenic (As) (mg/L)	BDL	0.01	No Relaxation
7	Total Iron (Fe) (mg/L)	0.08	1	No Relaxation
8	Manganese (Mn) (mg/L)	BDL	0.1	0.3
9	Total Coliform (Nos./100 ml)	NIL	Shall not be detectable in any 100 ml sample	
10	Fecal Coliform (Nos./100 ml)	NIL	Shall not be detectable in any 100 ml sample	

BDL: Below Detection Limit


DIRECTOR

SCHOOL OF WATER RESOURCES ENGINEERING
JADAVPUR UNIVERSITY

Prof. (Dr.) Pankaj Kumar Roy
Director

School of Water Resources Engineering
Jadavpur University


REGISTRAR

JADAVPUR UNIVERSITY

Registrar
JADAVPUR UNIVERSITY