



MADURAI CORPORATION
SANITARY CERTIFICATE


For the Club:


NARAYANA e-TECHNO SCHOOL
76/2A1,76/2A2,76/2A3,Vandiyur 1st Bit,
Madurai-625020.


CERTIFICATE

I here by declare that I have caused to be inspected "NARAYANA e-TECHNO SCHOOL" 76/2A1,76/2A2,76/2A3,Vandiyur 1st Bit Madurai-625020.building and premises on 28.08.2024 and certify that the accommodation provided for Hall is sufficient and properly ventilated and lighted. And that the building is maintained in substantial repairs, that it is neat and clean. That the latrine arrangements areadequate and satisfactory,that the supply of drinking water is wholesome and that in all other necessary aspect the sanitation in **SATISFACTORY**.

This certificate is valid for one year from the date of issue.


SANITARY OFFICER
Zone - I 29/8/24.
Madurai Corporation.


SANITARY INSPECTOR
Ward No - 40
Madurai Corporation.

Countersigned

City Health officer
Madurai Corporation.
CITY HEALTH OFFICER
MADURAI CORPORATION



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

32

DISTRICT WATER TESTING LABORATORY

Ganesh Nagar, Near Law College Students Hostel,
Melur Road, Madurai-625 007.

Phone: 0452 - 3568627

E-mail: wtlmdu@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No:	2024/MDU/1385	Report Date :	18.06.2024
Invoice Details:	197/Dt.13.06.2024/Amt.Rs.2360/-		

Client Name & Address : Narayana E-Techno School,
Contact No / Email.ID : S.No.76/2A1,76/2A2,76/2A3,
Vandiyur Ist Bit,
Madurai-625020.

Sample Name : Water
Sample Description : RO Water
Sample Submitted by : Customer
Location & Date : Above Address & 13.06.2024
Quantity of sample Received : 2 Litres
Sample Container : Jerry Cane – Good condition
Sample Condition on Receipt : Good
Sample Received On : 13/06/2024
Test Commenced on : 14/06/2024
Test Completed on : 18/06/2024

S.No	Parameters	Test Method	Unit	Sample Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit
1	pH at 25°C	IS 3025 Part 11-2022	-	6.64	6.5-8.5	6.5-8.5
2	Total Hardness as CaCO ₃	IS 3025 Part 21-2009 (RA:2019)	mg/L	16	200	600
3	Total Alkalinity as CaCO ₃	IS 3025-Part 23-2023	mg/L	10	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA:2019)	mg/L	15	250	1000
5	Sulphate as SO ₄	IS 3025-Part 24sec (1)-2022	mg/L	Less than 5	200	400
6	Nitrate as NO ₃	APHA 24th Edition 2023- 4500 -NO ₃ B	mg/L	Less than 2	45	45
7	Fluoride as F	APHA 24th Edition 2023 - 4500- F-D	mg/L	0.46	1.0	1.5

Remarks: The above water sample is confirmed to IS: 10500:2012 Drinking Water Specification with respect to above tested parameters.

.....End of the report.....

B. Karuthapandian
18/6/24
Reviewed and Authorised by
B. Karuthapandian, B.E., M.Tech.
Assistant Water Analyst (i/c)

Note:

- The test results relate only to the items tested.
- The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
- The test sample will be retained for 15 days.
- The Result applied to the sample as Received basis

Issue No./Date	01/01.10.2021	Amend. No/ Date	01/29.04.2024	Page No	1 of 3
----------------	---------------	-----------------	---------------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Ganesh Nagar, Near Law College Students Hostel,
Melur Road, Madurai-625 007.

Phone: 0452 - 3568627

E-mail: wtlmdu@gmail.com


TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No:	2024/MDU/1385	Report Date :	18.06.2024
Invoice Details:	197/Dt.13.06.2024/Amt.Rs.2360/-		

S.No	Parameters	Test Method	Unit	Sample Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit
1	Appearance	Physical observation	--	Clear	-	-
2	Colour	APHA 23rd Edition 2017 4500 H+B	Hazen	Colourless	Agreeable	Agreeable
3	Odour	IS 3025 Part 5 : 1983	--	None	-	-
4	Turbidity	APHA 23rd Edition 2017 - 2130 B	NTU	0	1	5
5	Total Dissolved Solids	APHA 23rd Edition 2017 - 2540 C	mg/L	15	500	2000
6	Conductivity	APHA 23rd Edition 2017 - 2510 B	μS/cm	30	-	-
7	P - Alkalinity	IS 3025-Part 23-1983	mg/L	-	-	-
8	Calcium	APHA 23rd Edition 2017 - 3500 Ca B	mg/L	4	75	200
9	Magnesium	APHA 23rd Edition 2017- 3500 Mg B	mg/L	1	30	100
10	Iron	APHA 23rd Edition 2017- 3500 Fe B	mg/L	Less than 0.1	0.3	1
11	Manganese	APHA 23rd Edition 2017 - 3500 Mn B	mg/L	Less than 0.1	0.1	0.3
12	Ammonia	APHA 17th Edition-1989- 4500 NH3C	mg/L	Less than 0.1	0.5	0.5
13	Nitrite as NO ₂	APHA 23rd Edition 2017- 4500-NO2 B	mg/L	Less than 0.1	0.5	0.5
14	Total Phosphate as PO ₄	APHA 23rd Edition 2017 - 4500 P- D	mg/L	Less than 0.1	0.5	0.5
15	Oxygen Absorbance in 4hr	IS 3025 part 63	mg/L	0.6	-	-
16	Residual chlorine	IS / APHA	mg/L	Less than 0.1	0.2	0.5

.....Report Continues.....


Reviewed and Authorised by
B. Karuthapandian, B.E., M.Tech.
Assistant Water Analyst (i/c)

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test sample will be retained for 15 days.
4. The Result applied to the sample as Received basis

Issue No./Date	01/01.10.2021	Amend. No/ Date	01/29.04.2024	Page No	2 of 3
----------------	---------------	-----------------	---------------	---------	--------



TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

Ganesh Nagar, Near Law College Students Hostel,
Melur Road, Madurai-625 007.

Phone: 0452 - 3568627

E-mail: wtlmdu@gmail.com

323

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Test Report No:	2024/MDU/1385	Report Date :	18.06.2024
Invoice Details:	197/Dt.13.06.2024/Amt.Rs.2360/-		
Client Name & Address	: Narayana E-Techno School, S.No.76/2A1,76/2A2,76/2A3, Vandiyur Ist Bit, Madurai-625020.		
Contact No / Email.ID			
Sample Name	: Water		
Sample Description	: RO Water		
Sample Submitted by	: Customer		
Location & Date	: Above Address & 13.06.2024		
Quantity of sample Received	: 2 Litres		
Sample Container	: Jerry Cane – Good condition		
Sample Condition on Receipt	: Good		
Sample Received On	: 13/06/2024		
Test Commenced on	: 14/06/2024		
Test Completed on	: 18/06/2024		

The test result of sample received as follows

Sl. No	BACTERIOLOGICAL EXAMINATION:	Sample No. 2024/MDU/1385 Sample Result	BIS 10500-2012
			Max Limit
1	Standard plate count CFU/100ml	0	500 Organisms/ml
2	Total Coliform CFU/100ml	0	Nil/100 ml
3	Fecal coliform CFU/100ml	0	Nil/100 ml
4	Fecal Streptococcus CFU/100ml	0	Nil/100 ml

.....End of the report.....

Result: The given RO water sample is physically and chemically potable and bacteriologically not contaminated.


Reviewed and Authorised by
B. Karuthapandian, B.E., M.Tech.
Assistant Water Analyst (i/c)

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. The test sample will be retained for 15 days.
4. The Result applied to the sample as Received basis

Issue No./Date	01/01.10.2021	Amend. No/ Date	01/29.04.2024	Page No	3 of 3
----------------	---------------	-----------------	---------------	---------	--------