



ANNEXURE C
Appendix-VIII



BRUHAT BENGALURU MAHANAGARA PALIKE

Medical Officer OF Health, Mahadevapura Division, Bangalore-560048

NO: BBMP/MOH/MDP/PR/31 /2024-25

DATE:-25/06/2024

PROFORMA REGARDING NOC & SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Dr.Rakesh.N,** **Medical Officer of Health** and **Devraj.M, Senior Health Inspector** from **BBMP Health Department** Inspected the **Narayana e-Techno School, Sy No.86/4, Chalakere Village, K R Puram Hobli, Bengaluru East Taluk-560043.** On **25-06-2024** and found that the **Narayana e-Techno School** Institution. And is having provision for running water in the toilets and is maintaining the hygienic sanitation condition in the School building & the campus as per the norms prescribed by the Central /state/U.T.Govt.

The Above NOC is Valid for the Period of One Year from the date of Issue.

Signature with Seal :

Name

Designation

Dr. Rakesh.N
ಅರಸೀಕೆರೆ, ವಿದ್ಯಾಧಿಕಾರಿಗಳು
: Medical Officer of Health
ಮಹದೇವಪುರ ವಲಯ
:BBMP Mahadevapura Division.
ಬೆಂಗಳೂರು

To,

**Narayana e-Techno School,
Sy No.86/4, Chalakere Village,
K R Puram Hobli,
Bengaluru East Taluk,
Bengaluru-560043**



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT

Address of the sampling location :- NARAYANA E-TECHNO SCHOOL SY.No.86/4, Chalakere Village K.R. Puram Hobli, Bengaluru East Taluk, Bengaluru-560043.				Report date: 06/07/2024 Report Number: 0541 Reference: TRF Sample code: 0541 Date of Sample collection: 05/07/2024 Analysis start date: 05/07/2024 Analysis completion date: 06/07/2024 Sample quantity: 1 Liter	
Sample Particulars: R.O water					
Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	6.7	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	110.0	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) :2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	70.0	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	17.2	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	40.4	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	11.3	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	2.9	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	9.5	250	1000	IS 3025 (Part-32) : 1988
12	Sulphate as SO_4 , mg/l	1.4	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	Nil	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003
Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.					
Analysed by: <i>Megha K.S</i> Senior Analyst/Junior Analyst			Authorized Signatory: <i>Pavithra B.S</i> Technical Manager: Pavithra B.S RDWSD/WQMSP/TeR/01		



Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---