



Government Of West Bengal
Office Of The Divisional Fire Officer, Hooghly
West Bengal Fire & Emergency Services
G.T. Road, Bose Para, Mahesh-1, Serampore,
Hooghly, Pin :- 712202

Memo no.:IND/WB/FES/20182019/33796

Date: 14-12-2022

From:
Divisional Fire Officer, Hooghly
West Bengal Fire & Emergency Services

To: Narayana School Rishra
100, G. T. Road, Rishra, Hooghly - 712248

Sub: Renewal of Fire Safety Certificate of an existing (G+3) Storied Building Under Group of Educational Building in the Name & Style of 'NARAYAN SCHOOL RISHRA' at 100 G.T Road, P.O & P.S – Rishra , Dist – Hooghly, Pin- 712248

This is in reference to your application no. 0125191220200148 dated 18-10-2022 regarding the Renewal of Fire Safety Certificate of an existing (G+3) Storied Building Under Group of Educational Building in the Name & Style of 'NARAYAN SCHOOL RISHRA' at 100 G.T Road, P.O & P.S – Rishra , Dist – Hooghly, Pin- 712248

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free from any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way of the educational building.
2. The internal finish decoration of the building shall be made low flame spread conforming I.S. specification .
- 3 .To eliminate risk of fire hazard , good house keeping both for inside and out side of building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked wear and tear in them, particularly lines above false ceiling and ducts.
5. A fire control room including a closed circuit TV system will have to be maintained observe all floor of the building .
6. The notice of fire fighting and evacuation from the building shall be prepared at all the vulnerable place of the building.

7. " No Smoking " board should be displayed .
8. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and testing.
9. Mock fire practice and evacuation drill shall be performed periodically with all employees , owners of the building.
10. First Aid Fire fighting system shall be provided as per I.S. specification.
11. If required old line shall have to be replace with new lines, the cable shall always in M.S. conduit pipes continuously bonded to the earth.
12. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register .
13. Floor numbers and directional sign of escape route shall be displayed prominently .
14. This Fire Safety Certificate is valid for three (3) years and has to be renewed after three years from the date of issue of the certificate as per notification , Govt . of west Bengal vide notification No- 629/L, Dated- 17/04/2018 Certifying about the satisfactory services , performance of all life and fire safety arrangements and installation of the educational building.

Divisional Fire Officer, Hooghly
West Bengal Fire & Emergency Services