RAJKOT MUNICIPAL CORPORATION
HEALTH BRANCH

DR. AMBEDAKAR BHAVAN, ROOM NO. 1, 3rd FLOOR, DHEBAR ROAD, RAJKOT || MAIL : moh@rmc.gov.in

RMC/HEALTH/ 2256 DATE. 25/09/2026

HYGIENE WITH REGARD TO HEALTH AND SANITATION CONDITION CERTIFICATE

It is certified that an inspection team handed by Dr. J. L. Vakani (Medical Officer of Health) from Rajkot Municipal Corporation inspected Narayana e-Techno School at Single unit-1, Survey No. 612/p13/p1, O.P. No.3, T.P.S. No.24, F.P. No.3/17, Railnagar, Rajkot city (EAST), Rajkot, Gujarat on 25/09/2026. On the basis of water test report (attached) bearing No.2382/09/2026, Date:18/09/2026 of PUBLIC HEALTH ENGINEERING LABORATORY and found that Narayana e-Techno School has safe water facilities for the students and members of staff of the institution and is maintaining the hygiene sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T. Govt.

This Certificate is valid for an issued date to period of 1 year.

Municipal Corp. Health Branch

Signature with Seal

Medical Officer of Health
Rajkot Municipal Corporation
RAJKOT

To,
Narayana e-Techno School
Single unit-1, Survey No. 612/p13/p1,
O.P. No.3, T.P.S. No.24, F.P. No.3/17,
Railnagar, Rajkot city (EAST), Rajkot-360001

PRINCIPAL
NARAYANA e-TECHNO SCHOOL
RAILNAGAR, RAJKOT

P. H. E. Laboratory
G.W.S. & S.B.
1st Floor, Chimanbhai Patel Vikas Bhavan, Jamnagar Road
RAJKOT - 360001
Phone : (0281) 2441521

જાહેર આરોગ્ય ઇજનેરી પ્રયોગશાળા
ગુ. પા. પુ. અને ગ.વ્ય.બોર્ડ,
પહેલો માળ, ચીમનભાઇ પટેલ વિકાસ ભવન,
જામનગર રોડ, રાજકોટ- ૩૬૦૦૦૧
ફોન : (૦૨૮૧) ૨૪૪૧૫૨૧

E mail : phel.rjt@gmail.com

TC-4117

Test Report

Name & Address of Customer:-

*NARAYANA E - TECHNO SCHOOL

Nr. Swaminarayan Residency
Railnagar,
RAJKOT
DIS RAJKOT

Customer Reference No.: NILL

Sample Submitted by : Sender
Date of Sample Receipt : 16-Sep-26
Analysis Starting Date : 16-Sep-26
Analysis Completion Date : 17-Sep-26
ULR No.: -
Discipline : Chemical Testing **Group :** Water

Test Report No.:	2382/09/2026	**Date of Issue :**	18-09-26
Sample ID :	RCW-2382/09/2026	**Mode of Sample:**	-
Main Source :	GROUND	**Source :**	TUBE WELL WATER
Location :	IN PARKING		
Village :	RAJKOT	**Habitation :**	RAJKOT
Taluka :	RAJKOT	**District :**	RAJKOT
Latitude :	-	**Longitude :**	-
Kindly find herewith the Analytical Results.		**Sample Type:**	**Drinking Water**

Sr. No.	Parameter	Unit	Reference Method :	Analytical Value
1	Colour	CU	APHA (24th Ed 2023), Method: 2120 B	<1
2	Turbidity	NTU	APHA (24th Ed 2023), Method: 2130 B	0.37
3	pH at 25°C	-	APHA (24th Ed 2023) Method: 4500 H^+ B	7.14
4	Conductivity at 25°C	µS/cm	APHA (24th Ed 2023) Method: 2510 B	397
5	Total Dissolved Solids	mg/L	APHA (24th Ed 2023) Method: 2540 C	254
6	Total Hardness (as $CaCO_3$)	mg/L	APHA (24th Ed 2023) Method: 2340 C	124
7	Calcium (as Ca^{+2})	mg/L	APHA (24th Ed 2023) Method: 3500-Ca^{+2} B	40
8	Magnesium (as Mg^{+2})	mg/L	APHA (24th Ed 2023) Method: 3500-Mg^{+2} B	20
9	Chloride (as Cl^-)	mg/L	APHA (24th Ed 2023) Method: 4500-Cl^- B	88
10	Sulphate (as SO_4^{-2})	mg/L	APHA (24th Ed 2023) Method: 4500-SO_4^{-2} E	59
11	Nitrate (as NO_3^-)	mg/L	APHA (24th Ed 2023) Method: 4500-NO_3^- B	3.14
12	Fluoride (as F^-)	mg/L	APHA (24th Ed 2023) Method: 4500-F^- C	0.16
13	Total Alkalinity (as $CaCO_3$)	mg/L	APHA (24th Ed 2023) Method: 2320 B	140

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter
2. The sample will be destroyed after retention time unless otherwise specified specially
3. The Report shall not be reproduced expect in full, Without approval of the laboratory
4. Please refer back page for IS 10500 2012 (2nd Revision) limits
5. *This Information (Name and address of the customer, details of the sample) are provided by the customer

Analysed By :

Chemist / Technical manager

Checked & Approved By:

Riddhi

(RIDDHI VACHHANI)
Authorised Signatory

---------- **End of the Test Report** ----------

O.W.No. PHEL/RJT/C. Report/ 149 /of 2026, Dt. 23 / 9 /2026

PRINCIPAL
NARAYANA e-TECHNO SCHOOL
RAILNAGAR, RAJKOT

PUBLIC HEALTH ENGINEERING LABORATORY
GUJARAT WATER SUPPLY SEWERAGE BOARD RAJKOT
1St Floor Chimanbhai Patel Vikas Bhavan Jamnagar Road Rajkot-360001
Phone No (0281) 2441521
Email - phel rjt@gmail.com

REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address

*NARAYANA E - TECHNO SCHOOL
Nr. Swaminarayan Residency
Railnagar Rajkot

Sender's Ref. No. : NILL
Ref. Date : 16/09/2026
Date & Time of Commencing Examination : 16/09/2026
Sample collected by : Sender

RBW No.	**2662**
Date of Collection	16/09/2026
Date of Arrival at Lab.	16/09/2026
Source of Water Sample	*TUBE WELL / IN PARKING
Village	RAJKOT
Habitation	RAJKOT
Taluka	RAJKOT
District	RAJKOT
APHA, AWWA, 9221-D Presence - Absence Coliform Test, @ 37° C	---
APHA, AWWA, 9221-F Presence - Absence E-Coli Test, @ 37° C	---
APHA-9222B,IS-15185:2016,ISO 9308-1:2014 Total Coliform Test	< 2
APHA-9222D,IS-15185:2016,ISO 9308-1:2014 Therotolerant Fecal Coli form (E.Coli)	< 2
Free Chlorine (PPM)	NILL
OPINION FOR POTABILITY :	

Important Note:-

1) '>=' Indicates greater than or equal to, 2) '<' Indicates less than
NOTE : Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Rivision.
@ All Water Intended for Drinking -
(a) E. coli or Thermotolerant coliform bacteria shall not be detactable in any 100ml sample.
@ Treated Water Entering the Distribution system & Treated Water in the Distribution system
(a) E. coli or Thermotolerant coliform bacteria shall not be detactable in any 100ml sample.
(b) Total coliform bacteria shall not be detactable in any 100ml sample.
@ 0.2ppm Free Residual Chlorine at consumer end is recommanded.

1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.
2) This Report should not be taken as a basis to getting license from any Government authority.
3) After Collection of Bact. Sample, it must be preserved at 4ºC and submitted to laboratory within 24hrs.

Vishal
Microbiologist

Outward No : PHEL/RJT / 309 / of 2026, Date: 21 / 09 / 2026

PRINCIPAL
NARAYANA e-TECHNO SCHOOL
RAILNAGAR, RAJKOT